



Englishmen River Water Service Water Treatment Plant Expansion Project

Background

Today's presentation

- Results from the Phasing Options meeting
 - Re-scope project in phases to minimize impacts on water rates and development cost charges
 - Review of four phasing options
 - Selection of the best phasing option based on technical and cost criteria
 - Is a phased approach better than the pre-design option?

Water Demand and Planning Horizons

Pre-design

- 24 ML/d WTP by 2016
- Design based on industry standard practices
 - A planning horizon of 20 years (up to 2035)
 - Water demand projections that include a 25% safety factor
 - Uncertainties in population growth
 - changes in water use
 - Impacts of climate change on irrigation
 - Flexibility to expand as demand increases

Let us put water demand into context

- 2014 water demand for Parksville and Nanoose
 - Water demands are increasing
 - Existing river intake capacity is limited to 12.2 ML/d
- Groundwater wells
 - Current ERWS wells have a maximum capacity of 11.8 ML/d
 - New wells outside of ERWS are being developed in the same aquifer
 - Therefore existing wells/aquifer capacity declining over time
 - Need to reduce reliance on groundwater

Water Demand and Planning Horizons – Phased Approach

- Phase 1 WTP capacity of 16 ML/d (2016)
 - Minimum capacity *without* a safety factor
 - Typically not good industry practice
- Phase 2 expansion planned for 2024 to meet the 24 ML/d demand by 2026

Phased Expansion Options

Phased Expansion Options


- As a phasing option, can the new WTP be located at the existing intake site?
 - Short answer is no
 - Intake has limited capacity
 - 40 year old infrastructure
 - Capacity limited to approximately 12 ML/d
 - Location not suitable
 - In an existing neighbourhood (limited space)
 - Downstream of urban development (risk of contamination)
 - In a floodplain

Phased Expansion Options

- Expand WTP in two phases
- Phase 1
 - Meet demand
 - Meet regulatory requirements
 - Meet a budget of approximately \$20M
- Phase 2
 - Match the scope in Pre-design report
- Four options identified

Preliminary Design Report

- 24 ML/d of filtration, disinfection and corrosion control
- Transmission mains connecting to the Springwood and the Top Bridge reservoirs



Transmission Mains: PDR, Options 1, 2 and 4

Parksville System Improvements



Springwood Reservoir

Water Treatment Plant

Transmission Mains: PDR, Options 1, 2 and 4

Nanoose and Craig Bay Pump Station




Options


AT RIVER

AT WTP SITE


OPTION 1 [16 ML/d Disinfection]




OPTION 2 [16 ML/d Disinfection]



OPTION 3 [16 ML/d Disinfection, 8 ML/d Filtration]



OPTION 4 [16 ML/d Disinfection, 8 ML/d Filtration]




Phased Expansion Options

- All phased options require compromises
- Identified options that meet the budget and require the least compromises
- A few examples:
 - Partial treatment (disinfection only)
 - Reduced capacity (filtration only in a portion of the flow)
 - Less operational flexibility
 - Limited or no use of WTP during high turbidity events in the summer
 - Some infrastructure that would be abandoned in Phase 2

Option 1: 16 ML/d Disinfection

- 16 ML/d of disinfection and corrosion control
- Membrane filtration deferred to Phase 2
- Phase 1 includes the WTP building including foundations and buried tanks
- Transmission mains connecting to the Springwood and the Top Bridge reservoirs




Option 1: 16 ML/d Disinfection

■ Advantages

- Phase 1 infrastructure re-usable for the future expansion
- Improved operation of distribution system (mixing groundwater and surface water at reservoirs)


■ Disadvantages

- Does not meet IH 4.3.2.1.0
- Operation limited to low color and turbidity days (Summer use only)
- 1.5 years to add filtration (delivery, installation and commissioning)



Option 2: 16 ML/d Disinfection + Chemical Facility

- 16ML/d of disinfection and corrosion control
- Membrane filtration deferred to Phase 2
- Same treatment performance and capacity as Option 1
- Defers construction of WTP foundation/building except chemical storage facility




Option 2: 16 ML/d Disinfection + Chemical Facility

■ Advantages

- Phase 1 infrastructure re-usable for the future expansion (with modifications)
- Improved operation of distribution system (mixing groundwater and surface water at reservoirs)

■ Disadvantages

- Does not meet IH 4.3.2.1.0
- Operation limited to low color and turbidity days (Summer use only)
- Most WTP infrastructure deferred to Phase 2
- 2.5 years to add filtration (tender, delivery, installation and commissioning)




What are the filtration options in Phase 1?

- Pre-design uses an engineered filtration system that is appropriate for larger facilities (economy of scale)
- Making the WTP smaller and adding the same filtration system would exceed the budget
- To meet the Phase 1 budget with filtration, need trade-offs:
 - Packaged filtration systems
 - (cost effective up to 16 ML/d)
 - No high recovery
 - Slab on grade construction
- Phase 2
 - Separate WTP building
 - Engineered filtration system




Option 3: 16 ML/d Disinfection + 8 ML/d Filtration

- 16 ML/d of disinfection and corrosion control, 8 ML/d packaged filtration
- Need to defer construction of full transmission mains to offset cost of filtration



Option 3: Transmission Mains




Option 3: 16 ML/d Disinfection + 8 ML/d Filtration

■ Advantages

- Meets all IH 4.3.2.1.0 requirements.
- Year round operation
- Relief to the groundwater wells during the winter
- Quick filtration expansion to 16 ML/d (5 months)


■ Disadvantages

- Additional cost to integrate Phases 1 and 2
- Operational complexity in distribution system (no blending)
- Watermain route on Martindale prone to flooding, abandoned for Phase 2
- Additional 1.5 year to implement Phase 2



Option 4: 16 ML/d Disinfection + 8 ML/d Filtration

- 16 ML/d of disinfection and corrosion control, 8ML/d packaged filtration
- All transmission mains to Springwood and Top Bridge reservoirs
- Same as Option 3 but with construction of all transmission mains




Option 4: 16 ML/d Disinfection + 8 ML/d Filtration

■ Advantages

- Meets all IH 4.3.2.1.0 requirements
- Year round operation
- Relief to the groundwater wells during the winter
- Quick filtration expansion to 16 ML/d
- Flexibility to provide consistent blended water (filtration & direct connection to reservoirs)

■ Disadvantages

- Additional cost to integrate Phases 1 and 2
- Additional 1.5 year to implement Phase 2



Treatment Provided


Process	PDR	Option 1	Option 2	Option 3	Option 4
Vortex Sand Separators	✓	✗	✗	✓	✓
Fine Strainers	✓	✓	✗	✓	✓
Coagulation	✓	✗	✗	✓	✓
Membranes – UF or MF	✓	✗	✗	✓	✓
UV Disinfection	✓	✓	✓	✓	✓
Chlorination	✓	✓	✓	✓	✓
Corrosion Control	✓	✓	✓	✓	✓
Residuals	✓	✓	✓	✓	✓

Evaluation of Options

Evaluation Criteria and Weighting

Primary Criteria	Secondary Criteria
Water Quality	<ul style="list-style-type: none">• Compatibility with IH 4.3.2.1.0 and disinfection by product requirements• Consistent aesthetics
Technical Considerations	<ul style="list-style-type: none">• Ease of operation of distribution system• Performance reliability• Flexibility for interim expansion• Compatibility with site• Shift dependence from ground water to surface water
Social Considerations	<ul style="list-style-type: none">• Relative risk and impact of requiring boiled water advisory or water restrictions• Impacts to resident by phasing construction of water transmission mains
Natural Environmental Considerations	<ul style="list-style-type: none">• All options deemed equal in this category
Economic Considerations	<ul style="list-style-type: none">• Captured in capital cost estimates

Evaluation Criteria and Weighting



Technical Scoring

	Option 1	Option 2	Option 3	Option 4
	16 ML/d Disinfection	16 ML/d Disinfection + Chem. Facility	16 ML/d Disinfection + 8 ML/d Fltr.	16 ML/d Disinfection + 8 ML/d Fltr.
Raw Score	35	25	57	75
Weighted Score	3.0	2.3	7.3	8.6
Rank by Weighted Score	3	4	2	1


Capital Cost Estimate

	PDR	Option 1	Option 2	Option 3	Option 4
Total – 2016	\$35.16 M	\$25.16 M	\$21.59 M	\$23.11 M	\$24.32 M
Total – 2018/2024	\$1.83 M	\$14.00 M	\$17.66 M	\$17.62 M	\$16.41 M
Total Capital Cost	\$36.98 M	\$39.17 M	\$39.25 M	\$40.73 M	\$40.74 M

Best Value Option

■ Benefits and costs compared:

- Total costs Phase 1 and 2
- Cost per point
- Option 4: best value



Recommendation

- For a phased option to be more financially attractive than the PDR
 - Lower capital cost, and/or
 - Phase 2 be implemented in 20 years or later
- Analysis indicates
 - Phased options have a lower cost for Phase 1 compared to the PDR
 - Phase options have a higher overall project cost compared to the PDR
 - Phase 2 expansion must start within 8 years to meet 2026 water demands (no safety factor)

- Proceed with design outlined in the Pre-Design Report (PDR)